



LEGEND

1. Access floor panel
2. 1/4" - 20 X 1-3/4" cornerlock screw
3. 8 ga. die formed galv. steel head
4. Steel stud 3/4" - 10 UNC
5. Nut with vibration proof locking device
6. B800 base with 7/8" sq. galv. tubing
7. Die formed embossed galv. steel base

PEDESTAL SPECIFICATIONS

Pedestal Assembly

- Assembly up to 24" FFH shall provide a 5,000 lb. axial load without permanent deformation.
- Assembly shall provide a 2" total adjustment.
- Standard finished floor heights from 6" to 24". For other finished floor heights please contact the Tate Technical Hotline @ 800-231-7788. For seismic conditions, refer to seismic submittal details.
- Overturning moment of 1,000 in./lbs. when Tate ASP recommended pedestal adhesive is utilized.

Pedestal Head

- 8 ga. die formed galvanized steel pedestal head and projection welded stud with adjustment nut.
- Pedestal head shall be tapped for engagement of cornerlock screws.
- Steel stud shall be 3/4" - 10 UNC roll formed.
- Nut shall be 3/4" - 10 UNC with corrosion resistant coating..
- Stud shall provide an anti-rotation feature when engaged with the pedestal base assembly.

Pedestal Base

- Base to be at least 16" square and galvanized steel.
- Pedestal tube shall be 7/8" square galvanized tubing.

Perimeter

- Perimeter pedestal shall provide support for panels around columns, at walls and in corners.

